

VOC Content Test Certificate

Thursday 26th March 2020

Supplier: Forbo Flooring Systems (23 Ormsby Place, Wetherill Park, NSW, 2164, Australia)

Sample Description: Eurocol Forbo 614 Eurostar Linoleum Adhesive

Date Tested: March 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 as detailed for adhesives as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia</p> <p align="center">Green Star Design & As Built V1.3-13.1.1B</p> <p align="center">Green Star Interiors V1.3-12.1.1B</p>	<p align="center">Eurocol Forbo 614</p> <p align="center">Eurostar Linoleum</p> <p align="center">Adhesive</p>
<p align="center">Wood Flooring and Laminate Adhesives and Sealants:</p> <p align="center">100 grams per Litre</p>	<p align="center">54 grams per Litre as VOC content</p> <p align="center">per material</p>
<p align="center"><i>We hereby certify that Eurocol Forbo 614 Eurostar Linoleum Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V2003044