



Accredited by
DIN CERTCO and IAAF
ISO 17025 (STS411)

Forbo Flooring
P.O. Box 13
NL-1560 AA Krommenie

September 7, 2006

TEST REPORT

Lab Results

IST Reference 6864-B EN/Kol/gl
Subject Covering for Sportshall Surfaces
Testing acc. EN 14904

Material tested

Name **Marmoleum Sport**
Thickness: 4 mm

Delivery of Samples

Date August 14, 2006
Amount 3 pieces 30 x 20 cm
Design 83195
IST Sample Nr. 6040

Testing

Determination of Sliding Coefficient, Remaining Indentation
Specular Gloss and Specular Reflectance
acc. EN 14904:2005
Lab Climate 51% rH, 22°C
Tests used are covered by ISO 17025 Accreditation (STS411)

This reports consists of 2 pages.
Reproduction or printing of this report is only permissible in whole and conformity with the original



Test Results

Test	Result	Requirement acc. EN 14904
Scale Reading, dry acc. EN 14904 μ	98	80-110
Remaining Indentation acc. DIN 18032-2 mm	0.05	none
Specular Gloss 60° angle 85° angle	---- 2	none <30 mat surfaces . <45 finished surfaces
Specular Reflectance	34.4 – 35.4	to be specified only



Dipl. Ing. H.J. Kolitzus