

# Certificate

On 31<sup>st</sup> January 2007 Eurofins Environment A/S received a sample of a floor covering with the name

## Eternal Forbo Flooring Systems

The floor covering sample has been selected by Forbo-Novilon B.V. as being representative for the floor coverings of the type Eternal.

The emissions were tested according to the AgBB-scheme and guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see test report no. 758358.

### Evaluation of the test result according to AgBB/DIBt guidelines:

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m<sup>3</sup>.
- The sum of SVOC after 28 day was below the limit of 0.1 mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.

---

**The tested product complies with the requirements of DIBt (June 2004) in combination with the NIK values from AgBB (September 2005) for use in the indoor environment.**

23<sup>rd</sup> May 2007



---

Thomas Neuhaus  
Environmental Engineer



---

Inge Bondgaard  
M.Sc. (Chemistry)

Eurofins Environment A/S  
Smedeskovvej 38  
DK-8464 Galten /  
Denmark

Tel +45 70 22 42 66  
Fax +45 70 22 42 55