

Forbo Flooring B.V.
Industrieweg 12
1566 JP Assendelft
NETHERLANDS

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

voc@eurofins.com
www.eurofins.com/voc-testing

Date
28 November 2014

AgBB Test Report

1 Sample Information

Sample identification	DeskTop
Batch no.	52402
Production date	18-09-2014
Product type	Flooring
Date when sample was received	15/10/2014
Testing (start - end)	21/10/2014 - 18/11/2014

2 Evaluation of the Results

The tested product complies with the requirements of DIBt (October 2010) and AgBB(June 2012).

Parameter	Test after 3 days		Test after 28 days	
	Concentration mg/m ³	Limit value mg/m ³	Concentration mg/m ³	Limit value mg/m ³
TVOC	0.13	≤ 10	0.062	≤ 1.0
TSVOC	<0.005	-	<0.005	≤ 0.1
R-value (dimensionless)	0.29	-	0.13	≤ 1
Total VOC without NIK	<0.005	-	<0.005	≤ 0.1
Total carcinogens	<0.001	≤ 0.01	<0.001	≤ 0.001

The results are only valid for the tested sample(s).
This report may only be copied or reprinted in its entirety, parts of it only with a written acceptance by Eurofins.