

# Attestation

## AgBB

On 13 February 2019, Eurofins Product Testing A/S received a sample of textile flooring with the product name:

### Diffusion

supplied by

### Forbo Flooring UK Ltd.

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 392-2019-00064004\_C\_EN.

#### **Evaluation of the emission test result according to AgBB:**

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
  - The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m<sup>3</sup>.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m<sup>3</sup>.
  - The sum of SVOC after 28 day was below the limit of 0.1 mg/m<sup>3</sup>.
  - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
  - The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
  - Formaldehyde after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
- 

**The tested product complies with the requirements of AgBB including the LCI-values (August 2018) for use in the indoor environment.**

1 April 2019



Malene Laugesen  
Analytical Service Manager



Janne Rothmann Norup  
Analytical Service Manager