

# Attestation

## AgBB

On 3 November 2015, Eurofins Product Testing A/S received a sample of textile flooring with the product name:

### Outline

supplied by

### Forbo Flooring UK Ltd.

The emissions were tested according to AgBB and the guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 392-2015-00339701\_D\_EN\_rev1.

#### Evaluation of the emission test result according to AgBB:


- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC (“TVOC”) after 3 days was below the limit of 10 mg/m<sup>3</sup>.
- The sum of VOC (“TVOC”) after 28 days was below the limit of 1 mg/m<sup>3</sup>.
- The sum of SVOC after 28 day was below the limit of 0.1 mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
- Formaldehyde after 28 days was below the limit of 120 µg/m<sup>3</sup>.

**The tested product complies with the requirements of DIBt (October 2010) in combination with the NIK values from AgBB (June 2012) for use in the indoor environment.**

22 December 2015



Lise L. Clement  
Chemist



Janne R. Norup  
Chemist