

Attestation

European National Regulations on VOC emissions

On 17 January 2022, Eurofins Product Testing A/S received a sample of a linoleum with the product name:


Marmoleum Acoustic Topshield Pro

supplied by

Forbo Flooring BV

The emissions were tested according to the regulations in Germany, France, Belgium and Italy. The test is in accordance with German AgBB (2018) and the guidelines of the DIBt (2010), the German ABG (2018), the French legislation of 2011 on emission classes as specified in decree no 2011-321, the Belgian Royal Decree C-2014/24239 and the Italian CAM decree 11, section 2.3.5.5 (2017). Sampling, testing and evaluation were performed according to EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 (see the test report no. 392-2022-00019701_A_EN)

The tested sample complies with the European regulations as mentioned below:

- French VOC Regulation of March and April 2011 showing emission class: 
- German ABG/AgBB
- Belgian VOC
- Italian CAM
- The total of all VOC ("TVOC") was below 10 µg/m³ in toluene equivalents after 28 days.

The tested product complies with referenced European regulations as of 19 May 2022.

19 May 2022


Laura Hartung Sørensen
Analytical Service Manager


Janne Rothmann Norup
Analytical Service Manager