

Emission Test Certificate

Friday July 31st, 2009

Supplier: Forbo Flooring Systems (23 Ormsby Place, Wetherill Park NSW 2164)

Sample Description: Surestep PUR vinyl flooring

Date Tested: March 2006 (Tested by Eurofins Environmental A/S – ISO17025 Accredited)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Office Design IEQ-13</p> <p>Green Star Office Interiors IEQ-11</p>	<p>Surestep PUR</p>
<p>Total Volatile Organic Compound emission rate <0.5 mg/m²/hr (24 hours)</p>	<p>Total Volatile Organic Compound emission rate 0.3 mg/m²/hr (24 hours)</p>
<p>4-Phenylcyclohexene emission rate <0.05 mg/m²/hr (24 hours)</p>	<p>4-Phenylcyclohexene emission rate <0.01 mg/m²/hr (24 hours)</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV090732