



Forbo-Novilon B.V.  
Report No. FO 2207-1329

# Cleanroom<sup>®</sup> Suitable Materials

Sphera Element  
Biological Resistance: good

## FLOORING & COATING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Forbo-Novilon B.V.**  
KA Coevorden, The Netherlands

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FO 2207-1329.

The biological resistance of Sphera Element homogeneous vinyl (color: shell) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Procedure A (resistance to fungi)	1	good
Procedure C (resistance to bacteria)	0	excellent
<b>Overall result</b>	<b>good</b>	

The classification is based on a worst-case consideration of the Procedures A and C.

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

FO 2207-1329  
Report No. first document  
--  
Report No. current document

Stuttgart, October 11, 2022  
Place, date of first document issued  
--  
Place, current date

on behalf of 