TEST CONFIRMATION

Attestation of tests performed - Statement of conformity

Particle emission according to VDI 2083 Blatt 17:2013-06

Applicant:	**Forbo-Giubiasco SA** **Via Industrie 16** **6512 Giubiasco** **Switzerland**
Flooring system:	**Colorex EC**
Tested by:	Kiwa GmbH Polymer Institut, Flörsheim
Date of issue:	15.10.2021

The test results are described in test report P 13032-E of 20.09.2021.
The test of the particle emission as sphere-on-disc test with the material pair **Colorex EC** and **100Cr6** (sphere) was carried out according to VDI 2083 Blatt 17:2013-06.

Statement of conformity / Evaluation:

According to the DIN EN ISO 14644-1:2016-06 the achieved ISO classification is **class 3.** This corresponds to **GMP A.**

Flörsheim, 15.10.2021

Kiwa Polymer Institut
kiwa

i.V. Dr. Roland Augustin
- head of unit -

Kiwa GmbH
Polymer Institut
Quellenstraße 3
D-65439 Flörsheim
Germany

Tel: +49 6145 597 - 10
Fax: +49 6145 597 - 19
Web: www.kiwa.com
e-mail: Kiwa-Polymer@kiwa.com
Geschäftsführer:
Prof. Dr. Roland Hüttl
Dr. Gero Schönwaßer