



Forbo Flooring Coral nv Postbus 17 1560 AA KROMMENIE Netherlands

Your notice of Your reference 17-11-2020

Date 18-01-2021

Analysis Report 20.07046.04

Required tests:

EN 13501-1 (2019)

Sample id Information given by the client Date of receipt
T2024823 Coral Grip HD EV 17-11-2020

Vaisting Do Toronson

Kristina De Temmerman Order responsible

This report may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.

The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples. In assessing compliance with the specifications, we did not take into account the uncertainty on the test results.









T2024823 - Coral Grip HD EV **Reference:**

Information given by the client

EN 13501-1 (2019) Product standard

Production batch/piece number 0001014778 Date of carpet finishing 26-10-2020

FR treated yes FR-surface treatment no

Use-surface PVC non-woven

Backing layer Vinyl Total mass 8100 g/m^2 Total thickness 17 mm Surface structure Loop pile

Notified body No: 0493



Reference: T2024823 - Coral Grip HD EV

<u>Reaction to fire tests – Ignitability of building products subjected to direct impingement of flame - Single-flame source test</u>

Date of ending the test 15-01-2021

Standard used EN ISO 11925-2 (2010) Product standard EN 13501-1 (2019)

Floor covering

Deviation from the standard -

Conditioning 23°C, relative humidity 50%

Minimum 14 days or until constant mass is achieved

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test: they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Substrate Fibre cement board - density $(1800 \pm 200) \text{ kg/m}^3$

Mounting Loose-laid

Specimens have not been cleaned

Flame application time (s) 15
Flame application Surface

	Length		Width			
	1	2	3	4	5	6
Time to reach 150 mm mark (s)	*	*	*	*	*	*

^{* =} time to reach the mark > 20 s or mark not reached

Criteria Floorcoverings

time to reach the mark: -> 20 s: Class Efl $-\le 20 \text{ s}$: Class Ffl

Classification Class E_{fl}

Limitations

This classification document does not represent type approval or certification of the product.





Reference: T2024823 - Coral Grip HD EV

<u>Reaction to fire tests for floorings - Determination of the burning behaviour using a radiant heat source</u>

Date of ending the test 14-01-2021

Standard used EN ISO 9239-1 (2010) Product standard EN 13501-1 (2019)

Deviation from the standard -

Conditioning 23°C, relative humidity 50%

Minimum 14 days or until constant mass is achieved

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test: they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Test specimen

Substrate Fibre cement board - density (1800 \pm 200) kg/m³

Mounting Stuck down with

Eurocol 640 with spatula A2

Specimens have not been cleaned





Radiant heat flux

	Flame spread distance (cm)			Flame time	Heat flux *
	10 min	20 min	30 min		kW/m²
Length					
#1	15	15	15	12 min 18 s	10.4
Width					
#1	16	16	16	12 min 32 s	10.2
#2	16	16	16	12 min 15 s	10.2
#3	15	15	15	12 min 16 s	10.4
Average					10.3

^{*} Heat flux at the time of flame extinguishment or after a test duration of 30 minutes.

Fire classification in accordance with EN 13501-1 (2019)			
Class	EN ISO 11925-2 or CWFT	EN ISO 9239-1 (test duration = 30 min)	
$ m B_{fl}$	E_{fl}	heat flux $\geq 8.0 \text{ kW/m}^2$	
C_{fl}	E_{fl}	heat flux $\geq 4.5 \text{ kW/m}^2$	
${ m D_{fl}}$	E _{fl}	heat flux $\geq 3.0 \text{ kW/m}^2$	

Smoke production: Light attenuation

	Maximum (%)	Total (%.min)	
Length			
#1	60	323	
Width			
#1	58	354	
#2 #3	59	354 360	
#3	62	324	
Average		346	

Additional classification in accordance with EN 13501-1 (2019)		
smoke production ≤ 750%.min	s1	
smoke production > 750%.min	s2	





Reaction to fire classification: B_{fl}/s1

Glued on a non-combustible substrate*

* End use substrates of classes A1 or A2-s1,d0 (EN 13238:2010 § 5.2.2)

Limitations

This classification document does not represent type approval or certification of the product.