

# Attestation

## European National Regulations on VOC Emissions

On the 18<sup>th</sup> of August 2023, Eurofins Product Testing A/S received a sample of a linoleum with the product name:


**Marmoleum 2.5 mm**

supplied by

**Forbo Flooring BV**


The emissions were tested according to the regulations in Germany, France, Belgium and Italy. The test is in accordance with German AgBB (2021) and the guidelines of the DIBt (2010), the German ABG (2019), the French legislation of 2011 on emission classes as specified in decree no 2011-321, the Belgian Royal Decree C-2014/24239 and the Italian CAM DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022. Sampling, testing and evaluation were performed according to EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 testing standards (see the test report no. 392-2023-00373401\_A\_EN).

### The tested sample complies with the European regulations as mentioned below:

- French VOC Regulation of March and April 2011 showing emission class: 
- German ABG/AgBB
- Belgian VOC
- Italian CAM
- The total of all VOC ("TVOC") was below 10 µg/m<sup>3</sup> in toluene equivalents after 28 days.

### The tested product complies with referenced European regulations as of the 26<sup>th</sup> of September 2023.

27 September 2023



Mads Folkjær  
Analytical Chemist



Rasmus Verdier  
Analytical Service Manager