

# Confirmation

## LEED

On 27 November 2014, Eurofins Product Testing A/S received a sample of a flooring with the product name:

### 350 LiquidDesign

supplied by

### Forbo Eurocol Nederland B.V.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, AgBB, ISO 11890-2 and ASTM D6886 testing standards (See test report no. 392-2015-00186901\_03 and 392-2014-00291402A\_03).

**The test results of the tested coating indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of the EU Decopaint Directive 2004/42/CE

26 September 2017



Thomas Berring  
Analytical Service Manager