

Forbo Flooring B.V.  
Industrieweg 12  
1566 JP Assendelft  
NETHERLANDS

Eurofins Product Testing A/S  
Smedeskovvej 38  
8464 Galten  
Denmark

voc@eurofins.com  
www.eurofins.com/voc-testing

Date  
28 November 2014

## AgBB Test Report

### 1 Sample Information

|                               |                         |
|-------------------------------|-------------------------|
| Sample identification         | DeskTop                 |
| Batch no.                     | 52402                   |
| Production date               | 18-09-2014              |
| Product type                  | Flooring                |
| Date when sample was received | 15/10/2014              |
| Testing (start - end)         | 21/10/2014 - 18/11/2014 |

### 2 Evaluation of the Results

The tested product complies with the requirements of DIBt (October 2010) and AgBB(June 2012).

| Parameter               | Test after 3 days                  |                                  | Test after 28 days                 |                                  |
|-------------------------|------------------------------------|----------------------------------|------------------------------------|----------------------------------|
|                         | Concentration<br>mg/m <sup>3</sup> | Limit value<br>mg/m <sup>3</sup> | Concentration<br>mg/m <sup>3</sup> | Limit value<br>mg/m <sup>3</sup> |
| TVOC                    | 0.13                               | ≤ 10                             | 0.062                              | ≤ 1.0                            |
| TSVOC                   | <0.005                             | -                                | <0.005                             | ≤ 0.1                            |
| R-value (dimensionless) | 0.29                               | -                                | 0.13                               | ≤ 1                              |
| Total VOC without NIK   | <0.005                             | -                                | <0.005                             | ≤ 0.1                            |
| Total carcinogens       | <0.001                             | ≤ 0.01                           | <0.001                             | ≤ 0.001                          |

The results are only valid for the tested sample(s).  
This report may only be copied or reprinted in its entirety, parts of it only with a written acceptance by Eurofins.