

VERIFICATION OF CONFORMITY

Certificate No.: IN-GZ-CP-5627-23069

Applicant: **FORBO SHANGHAI CO., LTD**

Address: **ROOM 2112, NO1118 WEST YA'AN ROAD SHANGHAI**

It has been verified that

Product(s): **PLANET ORIENT HOMOGENEOUS PVC**

Product(s) Specification: **2.0mmx2000mmx20000mm**

are submitted by the applicant to the testing of the product in accordance with **ISO 16000-9:2006 /COR1-2007 &ISO 16000-6:2011&ISO16000-3:2011**. Based on the submitted sample(s),test was performed according to Decree **2011-321** relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is **A+** class.

on basis of the test report of **CANIN23009470801**.

The French **A+** example logo is as follows



This verification is valid from **Dec. 13, 2023** until **Dec. 12, 2026** and remains valid as long as the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Issue 1. Verified since **Dec. 13, 2023**

Authorised by



IN-GZ-CP-5627-23069



SGS-CSTC Standards Technical Services Co., Ltd.

16F Century Yuhai Mansion No.73, Fucheng Road, Haidian District, Beijing, China 100142

email CN.CONSTProdcert@sgs.com Website www.sgs.com

Bill Liang

Southern District Industrial Services Lab Manager

Disclaimer: Neither SGS-CSTC, any of its affiliated SGS sister organizations nor the SGS Group can be held responsible for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

VERIFICATION OF CONFORMITY

Certificate No.: IN-GZ-CP-5612-23069

..continued..

Results of examinations are as following:


Test Items	CAS NO.	28th days test results $\mu\text{g}/\text{m}^3$	Classes			
			C	B	A	A+
Formaldehyde	50-00-0	ND	>120	<120	<60	<10
Acetaldehyde	75-07-0	ND	>400	<400	<300	<200
Toluene	108-88-3	ND	>600	<600	<450	<300
Tetrachloroethylene	127-18-4	ND	>500	<500	<350	<250
Xylene	108-38-3&106-42-3&95-47-6	ND	>400	<400	<300	<200
1,2,4-Trimethylbenzene	95-63-6	ND	>2000	<2000	<1500	<1000
1,4-Dichlorobenzene	106-46-7	ND	>120	<120	<90	<60
Ethylbenzene	100-41-4	ND	>1500	<1500	<1000	<750
2-Butoxyethanol	111-76-2	ND	>2000	<2000	<1500	<1000
Styrene	100-42-5	ND	>500	<500	<350	<250
TVOC	/	4.9	>2000	<2000	<1500	<1000

Conclusion: Based on the submitted sample(s), test was performed according to Decree **2011-321** relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is **A+** class.

Statement: Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. Verified since Dec. 13, 2023

Authorised by



Disclaimer: Neither SGS-CSTC, any of its affiliated SGS sister organizations nor the SGS Group can be held responsible for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.