

# Attestation

## AgBB

On 24 June 2022 Eurofins Product Testing A/S received a sample of a Textile flooring with the product name:

**Infused**  
supplied by  
**Forbo Flooring UK Ltd.**

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 in the latest versions (see the test report no. 392-2022-00292602\_A\_EN).

### **Evaluation of the emission test result according to AgBB:**

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m<sup>3</sup>.
- The sum of SVOC after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.
- Formaldehyde after 28 days was below the limit of 0.1 mg/m<sup>3</sup>.

---

**The tested product complies with the requirements of AgBB including the LCI-values (June 2021) for use in the indoor environment.**

11 August 2022



Peter Alexander Skov  
Analytical Chemist, MSc. Eng. Chemistry



Janne Rothmann Norup  
Analytical Service Manager