



Forbo Novilon
Report No. FO 2004-1170

Cleanroom[®] Suitable Materials

Sphera EC/SD lacquer
Biological Resistance: very good

FLOORING & COATING

Single product Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

Forbo Novilon B.V.
Coevorden, the Netherlands

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FO 2004-1170.

The CSM classification of the Sphera EC/SD lacquer (550000) according to biological resistance is based on a worst-case consideration of both procedures A and C. Therefore growth intensity according to ISO 846 and VDI 2083 Part 18 has been transferred to the following classification:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	1	very good
Bacteria (Procedure C)	0	excellent
Overall result	1	very good

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

FO 2004-1170
Report No. first document
--
Report No. current document

Stuttgart, July 3, 2020
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA